

Business Impacts of Water Related Incidents

Explanation

The company monitors water-related operational interruptions in line with TSRS reporting requirements. For the fiscal years 2021–2024, assessments have been made based on İkizdere Hydroelectric Power Plant operational data.

- FY2021–2023: No water-related incidents with financial impacts.

- FY2024: One incident occurred due to heavy snowfall that blocked the intake and transmission tunnel, causing the plant to halt operations. This interruption resulted in total energy losses of 343.50 MWh, corresponding to approximately ₺778,876.62 (~USD 22,301.47).

Reporting Table (TRY)

Fiscal Year	Total actual and opportunity costs from water-related incidents (TRY)
FY 2021	0
FY 2022	0
FY 2023	0
FY 2024	₺778,876.62